

MUNICIPAL CORPORATION OF GREATER MUMBAI
MUMBAI FIRE BRIGADE



FIRE SAFETY COMPLIANCE CERTIFICATE

Nursing Home

Ward: 'C', Health Lic. No.761485681

Application No. : 1600018300

This Compliance Certificate is issued with respect to fire safety point of view only for Nursing Home Activity (excluding Canteen/Kitchen activity) & does not guarantee for the issuance of Trade License & if any time the premises is found non-Compliant w.r.t. Guidelines/Actions of MOH, A.E. (B&F) from 'C' Ward during Inspection of the Inspection cell/Compliance Cell of Ward or found any changes in the layout of the premises which is not with respect to the submitted Layout plan then this Fire Safety Compliance Certificate shall be considered as cancelled.

Name of Establishment : M/s K.G.Mittal Ayurvedic Hospital
 Address of Establishment : Netaji Subhash Road, Marine Drive, Mumbai – 400 002.
 Name of the Licensee : Mr. Parmeshwarlalji Mittal
 Trade : Nursing Home

This is the compliance with respect to previously issued Fire safety requirements for the above-mentioned Nursing home (excluding Kitchen/Canteen activity on the premises) and as per the undertaking cum indemnity bond submitted by the applicant. During the inspection, it was noticed that the Fire safety requirements issued earlier for Nursing Home activity are found complied with at this stage. However, if any non-compliance with Fire safety requirements is noticed in the premises later after the inspection, then the inspecting officer / approving officer or this department will not be responsible for the same.

However, it is the duty/responsibility of the Owner/ occupier of the premise to maintain the fire prevention & life safety measures in good repair & efficient condition all the time in accordance with the provision in Section 3 (1) of Maharashtra Fire prevention & Life Safety Measures Act. Also the certificate in the prescribed form (Form-B) from a Government approved Licensed Agency shall be submitted twice a year in the month of January & July, regarding the maintenance of Fire safety & life safety measures in accordance with the provisions in Section 3 (3), to the Nominated Officer / Chief Fire Officer.

REMARKS:

1. This Fire Safety compliance certificate is issued in accordance with the following fire safety requirement letters/ compliances produced;
 - (i) The Fire safety requirement letter u/no. 1600018300, dated 29/01/2022 for the Nursing Home activity.
 - (ii) The Fire safety requirement letter u/no. FBM/578/412, dated 02/10/1978 for fire-fighting safety requirements, and its compliance of respective requirements u/no FBM/580/87, dated 22/07/1980;
 - (iii) Fire Compliance certificate for the fire-fighting & fire-protection measures stipulated for the proposed addition/alternation vide online file u/no P3539/2019/(2/237)/C/342/New, dated

10/09/2020 against Fire Safety Requirement letter vide No. P3539/2019/(2/237)/C/342/New, dated 18/02/2020.

for a total 152 number of Beds including 02 Operation Theatres for the trade of Nursing Home in a total area of 7579.66 sq. mts.

2. This Fire safety compliance is issued only for the Nursing Home activity carried out on the premises on Part ground floor, 1st to 4th floor & part 5th floor only. This is excluding Kitchen/Canteen activity carried out on the premises. Hence necessary Fire safety compliance for the Kitchen/Canteen activity shall be obtained at the earliest till then no cooking activity shall be carried out on the premises.
3. Compliance with the above Fire Safety measures is for minimizing the chance of occurrence of fire through active & passive fire safety measures. Any Non-Compliance at any instance may cause the occurrence of fire which shall be the responsibility of the owner/ occupier.
4. This Fire Safety Compliance Certificate is to be renewed as and when it is required by the concerned MCGM authority with any additional fire safety measures if necessary.
5. Fire brigade department reserves the right to change/alter/add/delete the terms & conditions of these fire safety remarks as per the situation permits with prior intimation to the occupier.
6. This compliance certificate is issued from a fire safety point of view only, without prejudice to any legal matter pending in the court of law if any, and subject to verification of the authenticity of the existing structure by the competent authorities of the MCGM. The authenticity of the existing structure shall be verified by A.E. (B&F) of 'C' Ward.
7. It is noticed from the Online Status of Building & factory Checklist that premise is not commercial, hence the same shall be verified by A.E. (B& F) From 'C' Ward before issuing a License/ Fire Safety Compliance Certificate.
8. In this case the party has submitted receipts No. 712258242 dated 20.01.2022 towards scrutiny fees paid of Rs 40,000/- (Rupees Forty thousand only).

RAMESH
DAMODAR
BHOR

Digitally signed by RAMESH DAMODAR
BHOR
DN: cn=Personal, title=1938,
pseudoym=92528210awc0#238963d98
aadb162777ecac1ee51387d6c99f873b04
%, postalCode=00000, serialNumber=34455050803723866f1d
86a6270a270949f0a62c701803a2e2dc
69c9c, cn=RAMESH DAMODAR BHOR
Date: 2022.01.31 20:47:41 +05'30'

Santosh
Damodar
Sawant

Digitally signed by Santosh Damodar
Sawant
DN: cn=Santosh Damodar Sawant,
serialNumber=34455050803723866f1d
86a6270a270949f0a62c701803a2e2dc
69c9c, cn=SANTOSH DAMODAR SAWANT
Date: 2022.01.31 20:47:41 +05'30'

Inspecting Officer
Mumbai Fire Brigade

Approving Officer
Mumbai Fire Brigade

"The verification of Authenticity of structure, Mezzanine floor, Loft, Addition, Alteration, change of user, Amalgamation, authorized / Unauthorized construction, Encroachment, Area of the premises is not under the purview of this department and will not be responsible for any illegality and its consequences thereof."



Santosh
INCHARGE PRINCIPAL
K. G. Mittal Ayurved College
Netaji Subhash Road, Marine Drive,
Next to Taraporewala Aquarium,
Mumbai - 400 002.



SHAKTI FIRE SERVICES

Shop No. 5, Shree Rohidas Apt., Near Janvhi Heights, 100ft Road, Tisgaon, Kalyan (E) 421306., Maharashtra,
Mobile: 8425051775 GSTIN: 27CREPS1546Q1Z2 PAN Number: CREPS1546Q

FORM B

[See section 3 (3) and rule 4 (2)]

Six monthly Certificate to be given in every January and July by the owner or the occupier for compliance of the Fire Prevention and Life Safety Measures.

CERTIFICATE

Certified that I/we have carried out inspection of the Fire Prevention and Life Safety Measures installed in the following building or premises, namely*: -

Description and Location of Building or Premises

MITTAL FOUNDATION TRUST
- K.G. Mittal Hospital ,Netaji Subhash Road, Charni Road , 400002 .

I/ We further certify that these installations in the above-mentioned buildings are maintained in good repair and efficient conditions during the period 1st Jan 2025 to 30st Jun 2025, as required under the provisions of the Maharashtra Fire Prevention and Life Safety Measures Act, 2006 (Mah. III of 2007). The details of the inspection of installations carried out by me / we mentioned in the report appended herewith.

Place: **MUMBAI.**

Date: **22.07.2025**

Outward Ref :- **SFS/2024-25/17**

For Shakti Fire Services

License No. : **MFS-LA/RF-546**

License No. : **MFS-LA/RD-514**

Suresh Suresh Balbhim
Balbhim Shinde
 2025.07.22
 00:20:35 +05'30'
Shinde 2024.002.20895



Immit

INCHARGE PRINCIPAL
K. G. Mittal Ayurved College
Netaji Subhash Road, Marine Drive,
Next to Taraporewala Aquarium,
Mumbai - 400 002.

Signature of the Licensed Agency.



SHAKTI FIRE SERVICES

Shop No. 5, Shree Rohidas Apt., Near Janvhi Heights, 100ft Road, Tisgaon, Kalyan (E) 421306., Maharashtra,

Mobile: 8425051775

GSTIN: 27CREPS1546Q1Z2

PAN Number: CREPS1546Q

MITTAL FOUNDATION TRUST				
K.G. Mittal Hospital ,Netaji Subhash Road, Charni Road , 400002 .				
Sr.No.	Description	UOM	Quantity	Remarks
1	40 HP Hydrant Main Pump	Nos.	1	OK
2	12.5 HP Booster Pump	Nos.	1	OK
3	5 HP Booster Pump	Nos.	1	OK
4	Push Button	Nos.	2	OK
5	Main Fire Panel	Nos.	1	OK
6	Hose Reel Drum	Nos.	11	OK
7	Single Hydrant Valve	Nos.	11	OK
8	Single Hydrant Valve	Nos.	4	OK
9	CP Hose	Nos.	28	OK
10	Branch Nozzle	Nos.	2	OK
11	Double Door Hose Box	Nos.	2	OK
12	Branch Nozzle	Nos.	24	OK
13	Double Door Hose Box	Nos.	12	OK
14	2 Way Fire Brigade Intel	Nos.	1	OK
15	4 Way Fire Brigade Intel	Nos.	1	OK
16	Sidewall type Sprinkler	Nos.	36	OK
17	W/Co2 Type 9 Kg Fire Extinguisher	Nos.	5	OK
18	Co2 Type 4.5 Kg Fire Extinguisher	Nos.	2	OK
19	ABC Type 6 Kg Fire Extinguisher	Nos.	23	OK
20	ABC Type 2 Kg Fire Extinguisher	Nos.	4	OK
21	Fire Sand Bucket	Nos.	3	OK
22	Main Fire Alarm Control Panel with PA	Nos.	1	OK
23	MCP & Hooter cum speaker	Nos.	21	OK
24	Heat Detector	Nos.	7	OK
25	Smoke Detector	Nos.	209	OK
26	LPG Gas Leak Detector	Nos.	2	OK

Date : 22.07.2025

Outward Ref:- SFS/2024-25/17

For Shakti Fire Services

License No.: MFS-LA/RF-546

License No.: MFS-LA/RD-514


Suresh
Balbhim
Shinde

Suresh Balbhim
Shinde
2025.07.22 00:21:40
+05'30'
2024.002.20895



D. M. Wani
INCHARGE PRINCIPAL
K. G. Mittal Ayurved College
Netaji Subhash Road, Marine Drive,
Next to Taraporewala Aquarium,
Mumbai - 400 002.

Signature of the Licensed Agency



Govt. of Maharashtra
Directorate of Maharashtra Fire Service
Vidyanagri, Hans Bhugra Marg, Santacruz (East),
Mumbai - 400 098, Tel-022-26677555, Fax-022-26677666
www.mahafireservice.gov.in

FORM N
[(See section 9 (3) and rule 14]
License to act as a License Agency for the purpose of
Fire Prevention and Life Safety Measure

License No. MFS / LA / RF-546 / RD- 514

Date: 30.04.2022

License is hereby renewed under the provisions of sub-section (3) of section 9 of the Maharashtra Fire Prevention and Life Safety Measure Act, 2006 (Mah. III of 2007) to **M/s. Shakti Fire Services** having their registered office at **7, Kaveri Appt, Durga Matta Mandir, Kolsewadi, Kalyan (E), Thane 421306** and their contact details are Office Number:- 8108725698 and Email ID: shaktiifire101@gmail.com with PAN registration No. CREPS1546Q and GST No. 27CREPS1546Q1Z2 to act as a License Agency for the purpose of the said Act for execution of the fire prevention and life safety measures in relation to

1. Fire Fighting and Sprinkler System: Class D
2. Detection and Fire Suppression System: Class D

M/s. Shakti Fire Services shall not issue Form A or Form B under sub-section (3) of section 3 regarding the compliance of the fire prevention and life safety measures or maintenance thereof in good repair and efficient condition, without there being actual such compliance or maintenance failing which license granted / renewed shall be suspended or cancelled as per sub section (4) of section 9 and shall be liable for penalty under section 36 of the Act.

Subject to the provision of sub section (4) of section 9 of the said Act and rule 14 of the Maharashtra Fire Prevention and Life Safety Measures Rules, 2009, the license will be valid for a period from **04.11.2023 to 03.11.2025**

Hatyal Kiran
Asst Director
Digitally signed
by Hatyal Kiran
Date: 2023.11.10
16:34:08 +07'00'

Suresh Balbhim Shinde
2023.11.08 21:23:01
+05'30'
2023.00620360

Santosh Shridhar Warick
Digitally signed by
Santosh Shridhar
Warick
Date: 2023.11.10
16:08:37 +05'30'

(S S Warick)
Director
Maharashtra Fire Service

Digital Signature of Authorized Person to sign Form A or Form B

Note:

* in absence of digital sign of license holder (responsible to issue Form A or Form B) the license will be treated as invalid.



INCHARGE PRINCIPAL

Netaji Subhash Road, Marine Drive,
Next to Taraporewala Aquarium,
Mumbai - 400 098.



SHAKTI FIRE SERVICES

Shop No. 5, Shree Rohidas Apt., Near Janvhi Heights, 100ft Road, Tisgaon, Kalyan (E) 421306.,
Maharashtra,
Mobile: 8425051775 GSTIN: 27CREPS1546Q1Z2 PAN Number: CREPS1546Q

FORM B

[See section 3 (3) and rule 4 (2)]

**Six monthly Certificate to be given in every January and
July by the owner or the occupier for compliance of the Fire
Prevention and Life Safety Measures.**

CERTIFICATE

Certified that I/we have carried out inspection of the Fire Prevention and Life Safety Measures installed
in the following building or premises, namely*: -

Description and Location of Building or Premises

MITTAL FOUNDATION TRUST

K.G. Mittal Hospital, Netaji Subash Road, Charni Road, 400002

I/ We further certify that these installations in the above mentioned buildings are maintained in good
repair and efficient conditions during the period 1st July 2025 To 31st Dec 2025, as required under the
provisions of the Maharashtra Fire Prevention and Life Safety Measures Act, 2006 (Mah. III of 2007).
The details of the inspection of installations carried out by me / we mentioned in the report appended
herewith.

Place: MUMBAI.

Date: 22.02.2026

Outward Ref :- SFS/2025-26/102

For Shakti Fire Services

License No. : MFS-LA/RF-546

License No. : MFS-LA/RD-514

Suresh Suresh Balbhim
Balbhim Shinde
Shinde 2026.02.22
00:20:35 +05'30'
2024.002.20895



In charge
INCHARGE PRINCIPAL
K. G. Mittal Ayurved College
Netaji Subhash Road, Marine Drive,
Next to Taraporewala Aquarium,
Mumbai - 400 602.

Signature of the Licensed Agency.



SHAKTI FIRE SERVICES

Shop No. 5, Shree Rohidas Apt., Near Janvhi Heights, 100ft Road, Tisgaon, Kalyan (E) 421306.,
Maharashtra,
Mobile: 8425051775 GSTIN: 27CREPS1546Q1Z2 PAN Number: CREPS1546Q

CLIENT NAME	MITTAL FOUNDATION TRUST
ADDRESS	K.G. Mittal Hospital, Netaji Subash Road, Charni Road, 400002

Sr.No.	Description	UOM	Quantity
Fire Fighting System			
1	40 HP Hydrant Main Pump	Nos.	1
2	12.5 HP Booster Pump	Nos.	1
3	5 HP Booster Pump	Nos.	1
4	Push Button	Nos.	2
5	Main Fire Panel	Nos.	1
6	Hose Reel Drum	Nos.	11
7	Single Hydrant Valve	Nos.	11
8	Single Hydrant Valve	Nos.	04
9	CP Hose	Nos.	28
10	Branch Nozzle	Nos.	02
11	Double Door Hose Box	Nos.	02
12	Branch Nozzle	Nos.	24
13	Double Door Hose Box	Nos.	12
14	2 Way Fire Brigade Intel	Nos.	01
15	4 Way Fire Brigade Intel	Nos.	01
16	Sidewall type Sprinkler	Nos.	36
17	W/Co2 Type 9 Kg Fire Extinguisher	Nos.	05
18	Co2 Type 4.5 Kg Fire Extinguisher	Nos.	02
19	ABC Type 6 Kg Fire Extinguisher	Nos.	23
20	ABC Type 2 Kg Fire Extinguisher	Nos.	04
21	Fire Sand Bucket	Nos.	03
Fire Alarm System			
22	Main Fire Alarms Control Panel with PA	Nos.	01
23	MCP & Hooter cum speaker	Nos.	21
24	Heat Detector	Nos.	07
25	Smoke Detector	Nos.	209
26	LPG Gas Leak Detector	Nos.	02

Date : 22.02.2026

Outward Ref:- SFS/2025-26/102

For Shakti Fire Services

License No.: MFS-LA/RF-546

License No.: MFS-LA/RD-514

Suresh
Balbhim
Shinde

Suresh Balbhim
Shinde
2026.02.22 00:21:40
+05'30'
2024.002.20895



P. M. M. M.

INCHARGE PRINCIPAL
K. G. Mittal Ayurved College
Netaji Subhash Road, Marine Drive,
Next to Tarapurwala Aquarium,
Mumbai - 400 002.

Signature of the Licensed Agency